



MAIN DIAMETER	MINIMUM TRENCH WIDTH
14"	30"
16"	30"
18"	36"
24"	36"



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

## 14" THROUGH 24" TRENCH DETAIL - SHOULDER

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY: Robert A. Campbell

DATE: 5/8/13

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN\_716.DWG

PAGE:

**TREN\_716**