



NOTES:

1. NO PAVEMENT CUTS OR TRENCHES ARE ALLOWED IN PAVEMENT LESS THAN THREE YEARS OLD, UNLESS APPROVED BY THE COUNTY OF SACRAMENTO.
2. 1 1/2" DEEP GRINDING AND PAVING. GRIND TO LIP OF GUTTER, LANE LINE, OR CENTER OF TRAFFIC LANE, BUT 12" MINIMUM WIDTH.
3. SLURRY SEAL COAT TREATMENT SHALL BE APPLIED AT LOCATIONS SPECIFIED, AS SHOWN ON THE PLANS OR AS DIRECTED BY THE COUNTY OF SACRAMENTO.
4. STREET STRUCTURAL SECTION PER COUNTY OF SACRAMENTO STANDARDS.



**CITRUS
HEIGHTS
WATER
DISTRICT**

SERVICE LINE TRENCH DETAIL - PAVEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Melina Pieri

DATE: 4/19/17

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 19 APRIL 2017

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN_723SC.DWG

PAGE:

FOR CONSTRUCTION IN THE COUNTY OF SACRAMENTO

TREN_723SC