



**NOTE:**

- BOLT TORQUE ON ALL FITTINGS SHALL CONFORM TO MANUFACTURER'S SPECIFICATIONS.

1	EXISTING WATER MAIN	5	#10 INSULATED COPPER LOCATOR WIRE
2	FLEXIBLE COUPLING w/ 12" BARREL	6	CONCRETE THRUST BLOCK - SEE DETAIL TB_001
3	DUCTILE IRON PIPE - PC350, CONTINUOUS SECTION	7	#2 WASHED SAND - COMPACTED TO 90%
4	45° ELBOW - MECHANICAL JOINT W/ MEGA-LUG RESTRAINT GLANDS		



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

# UTILITY CROSSING

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY:

*Robert A. Churchill*

DATE: 5/8/13

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 8 MAY 2013

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: UC\_001.DWG

PAGE:

**UC\_001**