



1	3/4" BRONZE SADDLE - IPT	5	3/4" VALVE - FULL-PORT BALL, FIP x FIP or CTS x FIP w/ STAINLESS STEEL INSERT (3/4" CTS INSERT-51)
2	3/4" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (3/4" CTS INSERT-51)	6	3/4" BRASS STREET ELBOW
3	3/4" POLYETHYLENE TUBING - CTS ENDPORRE PE-4710 SODR 9 (250 PSI) OR EQUAL	7	#2 WASHED SAND COMPACTED TO 90%
4	3/4" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (3/4" CTS INSERT-51)	8	#10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX)



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

## 3/4" POLYETHYLENE WATER SERVICE

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY: Robert A. Churchill DATE: 9/25/14  
CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014
REVISED:
SCALE: N.T.S.
DESIGN: P.A.D.
CAD FILE: WS_078PE.DWG
PAGE: <b>WS_078PE</b>