



| | | | |
|---|---|---|--|
| 1 | 1" BRONZE SADDLE - IPT | 5 | 1" VALVE - FULL-PORT BALL, FIP x FIP or CTS x FIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52) |
| 2 | 1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52) | 6 | 1" BRASS STREET ELBOW |
| 3 | 1" POLYETHYLENE TUBING - CTS ENDOPORE PE-4710 SODR 9 (250 PSI) OR EQUAL | 7 | #2 WASHED SAND COMPACTED TO 90% |
| 4 | 1" BRASS STREET ELBOW - CTS COMP x MIP w/ STAINLESS STEEL INSERT (1" CTS INSERT-52) | 8 | #10 INSULATED COPPER LOCATOR WIRE (INSTALL INTO EXISTING METER BOX) |



1" POLYETHYLENE WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: *Robert A. Churchill* DATE: 9/25/14
 CITRUS HEIGHTS WATER DISTRICT

DRAWN: 25 SEP 2014

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_108PE.DWG

PAGE: **WS_108PE**