



**NOTES:**

- AIR/VACUUM VALVE AND 6' RISER SHALL BE PLUMB.
- MATERIAL BELOW AGGREGATE BASE SHALL BE COMPACTED TO 90% MINIMUM.

1	1' BRONZE SADDLE - IPT	15	1' x 2' SCH 80 NIPPLE - SLIP x MIP
2	1' CORPORATION STOP - FULL-PORT BALL, MIP x MIP	16	SCREEN - CHRISTY VC1
3	1' BRASS ELBOW	17	POLYMER CONCRETE BOX AND LID - ARMORCAST A6001761A-CV WITH POLYMER CONCRETE 12' EXTENSION - ARMORCAST A6001761 HOUSING - ARMORCAST P6002003X24-GRN OR CONCRETE BOX - CHRISTY 1324-H/20 WITH CONCRETE BOX EXTENSION - CHRISTY B24x12 LID AND HOUSING - PLACER WATERWORKS PW/AE118-M
4	1' BRASS STREET ELBOW - CTS COMP x MIP		
5	1' COPPER TUBING - TYPE K HARD		
6	1' VALVE - FULL-PORT BALL, CTS COMP x CTS COMP		
7	1' BRASS NIPPLE - LENGTH AS NEEDED		
8	1' GATE VALVE - NIBCO T-113B OR EQUAL		
9	1' x 4' BRASS NIPPLE	18	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
10	1' AIR/VACUUM VALVE - CRISPEN UL-10 OR EQUAL	19	3/4" CLEAN CRUSHED ROCK
11	1' SCH 80 PVC ADAPTOR - MIP x SLIP	20	CONCRETE VALVE BOX/LID - MARKED "WATER", CHRISTY F-8
12	1' SCH 80 PVC PIPE - SLIP x SLIP	21	6' RISER - SDR35 ONLY, CONTINUOUS SECTION
13	1' SCH 80 PVC ADAPTOR - FIP x SLIP	22	#2 WASHED SAND - COMPACTED TO 90%
14	1' SCH 80 PVC ELBOW - SLIP x SLIP		



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

## 1" AIR/VACUUM VALVE - BELOW GROUND

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY:

*Robert A. Chumbley*

CITRUS HEIGHTS WATER DISTRICT

DATE: 4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: AV\_412.DWG

PAGE:

**AV\_412**