



NOTES:

- AIR/VACUUM VALVE AND 6' RISER SHALL BE PLUMB.
- MATERIAL BELOW AGGREGATE BASE SHALL BE COMPACTED TO 90% MINIMUM.

1	2" BRONZE SADDLE - IPT	15	2" X 2" SCH 80 PVC NIPPLE - SLIP X MIP
2	2" CORPORATION STOP - FULL-PORT BALL, MIP X MIP	16	SCREEN - CHRISTY VC2
3	2" BRASS ELBOW	17	POLYMER CONCRETE BOX AND LID - ARMORCAST A6001761A-CV WITH POLYMER CONCRETE 12" EXTENSION - ARMORCAST A6001761 HOUSING - ARMORCAST P6002003X24-GRN OR CONCRETE BOX - CHRISTY 1730-H/20 WITH CONCRETE BOX EXTENSION - CHRISTY B30x12 LID AND HOUSING - PLACER WATERWORKS PW/AE17-810
4	2" BRASS STREET ELBOW - CTS COMP X MIP		
5	2" COPPER TUBING - TYPE K HARD		
6	2" VALVE - FULL-PORT BALL, CTS COMP X CTS COMP		
7	2" BRASS NIPPLE - LENGTH AS NEEDED		
8	2" GATE VALVE - NIBCO T-113B OR EQUAL	18	2" X 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
9	2" X 4" BRASS NIPPLE	19	3/4" CLEAN CRUSHED ROCK
10	2" AIR/VACUUM VALVE - CRISPEN UL-20 OR EQUAL	20	CONCRETE VALVE BOX/LID - MARKED "WATER", CHRISTY F-8
11	2" SCH 80 PVC ADAPTOR - MIP X SLIP	21	6" RISER - SDR35 ONLY, CONTINUOUS SECTION
12	2" SCH 80 PVC PIPE - SLIP X SLIP	22	#2 WASHED SAND - COMPACTED TO 90%
13	2" SCH 80 PVC ADAPTOR - FIP X SLIP		
14	2" SCH 80 PVC ELBOW - SLIP X SLIP		



**CITRUS
HEIGHTS
WATER
DISTRICT**

2" AIR/VACUUM VALVE - BELOW GROUND

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

CITRUS HEIGHTS WATER DISTRICT

DATE:

4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: AV_422.DWG

PAGE:

AV_422