



**NOTES:**

- BOLT TORQUE ON ALL FITTINGS SHALL CONFORM TO MANUFACTURER'S SPECIFICATIONS.
- SURFACE BELOW CRUSHED ROCK SHALL BE COMPACTED TO 95% MINIMUM.
- LID SHALL BE MARKED "WATER"

1	MJ CAP W/ 2' FIP OUTLET	10	2' x 3' BRASS NIPPLE
2	2' x 6' BRASS NIPPLE	11	2' BRASS 90° ELBOW
3	2' BRASS 90° ELBOW	12	2' PLUG - SCH 80 PVC, FINGER TIGHT
4	2' x 24' BRASS NIPPLE		NON-TRAFFIC AREA   SIDEWALK/DW   STREET
5	#10 INSULATED COPPER LOCATOR WIRE	13	BOX CARSON 1220-12   CHRISTY FL30TBX12   CHRISTY B1324BOX
6	2' BRASS COUPLING - ONE ONLY	14	LID CARSON 1220-4B   CHRISTY FL30T   CHRISTY B1324-61JH
7	2' BRASS NIPPLE - ONE ONLY, LENGTH AS NECESSARY TO ADJUST TO PROPER GRADE	15	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
		16	3/4' CLEAN CRUSHED ROCK
8	2' BRASS STREET ELBOW	17	CONCRETE BRICK - 2 1/4' x 3 3/4' x 7 1/2'
9	2' BRASS GATE VALVE - NIBCO T-113B OR EQUAL	18	CONCRETE THRUST BLOCK - SEE DETAIL TB_001



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

## 2" BLOW-OFF VALVE

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY:

*Robert A. Chubice*

CITRUS HEIGHTS WATER DISTRICT

DATE:

4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: BO\_511.DWG

PAGE:

**BO\_511**