



MAIN DIAMETER	MINIMUM TRENCH WIDTH
4"	18"
6"	24"
8"	24"
10"	30"
12"	30"



**CITRUS
 HEIGHTS
 WATER
 DISTRICT**

4" THROUGH 12" TRENCH DETAIL - NATIVE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Churchill

DATE: 4/13/2009

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN 711.DWG

PAGE:

TREN 711