



NOTES:

1. NO PAVEMENT CUTS OR TRENCHES ARE ALLOWED IN PAVEMENT LESS THAN THREE YEARS OLD, UNLESS APPROVED BY THE APPROPRIATE CITY OR COUNTY.
2. REQUIRED ONLY FOR PAVEMENT BETWEEN THREE AND FIVE YEARS OLD: 1 1/2" DEEP GRINDING AND PAVING. GRIND TO LIP OF GUTTER, LANE LINE, OR CENTER OF TRAFFIC LANE, BUT 12" MINIMUM WIDTH.
3. SEAL COAT TREATMENT SHALL BE APPLIED AT LOCATIONS SPECIFIED, AS SHOWN ON THE PLANS OR AS DIRECTED BY THE APPROPRIATE CITY OR COUNTY.

MAIN DIAMETER	MINIMUM TRENCH WIDTH
4"	18"
6"	24"
8"	24"
10"	30"
12"	30"



4" THROUGH 12" TRENCH DETAIL - PAVEMENT

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY: Robert A. Chubb DATE: 4/13/2009
 CITRUS HEIGHTS WATER DISTRICT

DRAWN: 13 APR 2009
REVISED:
SCALE: N.T.S.
DESIGN: P.A.D.
CAD FILE: TREN 713.DWG
PAGE: TREN 713