



MAIN DIAMETER	MINIMUM TRENCH WIDTH
14"	30"
16"	30"
18"	36"
24"	36"



**CITRUS
 HEIGHTS
 WATER
 DISTRICT**

14" THROUGH 24" TRENCH DETAIL - SHOULDER

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Chubice

DATE:

4/13/2009

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN 716.DWG

PAGE:

TREN_716