



NOTES:

1. NO PAVEMENT CUTS OR TRENCHES ARE ALLOWED IN PAVEMENT LESS THAN THREE YEARS OLD, UNLESS APPROVED BY THE APPROPRIATE CITY OR COUNTY.
2. REQUIRED ONLY FOR PAVEMENT BETWEEN THREE AND FIVE YEARS OLD: 1 1/2" DEEP GRINDING AND PAVING, GRIND TO LIP OF GUTTER, LANE LINE, OR CENTER OF TRAFFIC LANE, BUT 12" MINIMUM WIDTH.
3. SEAL COAT TREATMENT SHALL BE APPLIED AT LOCATIONS SPECIFIED, AS SHOWN ON THE PLANS OR AS DIRECTED BY THE APPROPRIATE CITY OR COUNTY.

MAIN DIAMETER	MINIMUM TRENCH WIDTH
14"	30"
16"	30"
18"	36"
24"	36"



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

# 14" THROUGH 24" TRENCH DETAIL - PAVEMENT

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY: *Robert A. Chubb*  
CITRUS HEIGHTS WATER DISTRICT

DATE: 4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: TREN 717.DWG

PAGE:

**TREN 717**