



NOTES:

- RISER SHALL BE PLUMB.
- VALVE OPERATING NUT SHALL BE CENTERED IN THE RISER AND FULLY ACCESSIBLE.
- MATERIAL BELOW AGGREGATE BASE SHALL BE COMPACTED TO 90% MINIMUM.
- CONTACT CITRUS HEIGHTS WATER DISTRICT FOR REBAR INSPECTION PRIOR TO POURING CONCRETE. (916) 725-6873
- REINFORCED CONCRETE PAD SHALL BE FINISHED WITH AN EDGING TOOL AROUND THE ENTIRE PERIMETER AND BROOMED AT RIGHT ANGLES TO THE DIRECTION OF TRAVEL.

1	VALVE BOX/LID - MARKED "WATER", CHRISTY G-5	5	3/4" CLASS 2 AGGREGATE BASE - 2" MINIMUM, MECHANICALLY COMPACTED TO 90%
2	8" RISER - SDR35 ONLY, CONTINUOUS SECTION		
3	#10 INSULATED COPPER LOCATOR WIRE	6	CONCRETE DOBIE w/ WIRE - 3' x 3' x 2'
4	REINFORCED CONCRETE PAD - 4" THICK x 30' SQUARE, TYPE II SIX-SACK PORTLAND CEMENT	7	3/8" (#3) REBAR - 2' INSIDE PERIMETER



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**

# WATER MAIN VALVE BOX - LANDSCAPE

**CITRUS HEIGHTS WATER DISTRICT**

APPROVED BY:  
*Robert A. Chubrie*  
CITRUS HEIGHTS WATER DISTRICT

DATE: 4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: VB\_810.DWG

PAGE:

**VB\_810**