



NOTES:

- RISER SHALL BE PLUMB.
- VALVE OPERATING NUT SHALL BE CENTERED IN THE RISER AND FULLY ACCESSIBLE.
- MATERIAL BELOW CONCRETE ENCASEMENT SHALL BE COMPACTED TO 95% MINIMUM.
- CONCRETE ENCASEMENT SHALL BE ALLOWED TO CURE 24 HOURS MINIMUM PRIOR TO FINISH PAVING.
- TRIANGULAR LID SHALL POINT IN THE DIRECTION OF THE MAIN WHICH IS ISOLATED BY THE VALVE.

1	VALVE BOX/LID - MARKED "WATER", SOUTH BAY FOUNDRY NO. 1237
2	CONCRETE ENCASEMENT AROUND VALVE BOX - TYPE II SIX-SACK PORTLAND CEMENT
3	8' RISER - SDR35 ONLY, CONTINUOUS SECTION
4	#10 INSULATED COPPER LOCATOR WIRE



**CITRUS
HEIGHTS
WATER
DISTRICT**

WATER MAIN VALVE BOX - STREET/DRIVEWAY

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY

Robert A. Chubb

DATE: 4/13/2009

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: VB_811.DWG

PAGE:

VB_811