



NOTES:

- VALVE OPERATING HANDLE SHALL BE CENTERED IN BOX AND FULLY ACCESSIBLE.
- MATERIAL BELOW CONCRETE ENCASUREMENT SHALL BE COMPACTED TO 95% MINIMUM.
- CONCRETE ENCASUREMENT SHALL BE ALLOWED TO CURE 24 HOURS MINIMUM PRIOR TO FINISH PAVING.
- LID SHALL BE MARKED 'WATER'

		NON-TRAFFIC AREA	SIDEWALK/DW	STREET		
1	BOX	CARSON 1220-12	CHRISTY FL30TBOX12	CHRISTY B1324BOX	5	3/4" CLASS 2 AGGREGATE BASE - 6' MINIMUM, MECHANICALLY COMPACTED TO 90%
2	LID	CARSON 1220-4B	CHRISTY FL30T	CHRISTY B1324-61JH	6	CONCRETE BRICK - 2 1/4" x 3 3/4" x 7 1/2"
3	#10 INSULATED COPPER LOCATOR WIRE				7	CONCRETE ENCASUREMENT AROUND VALVE BOX - TYPE II SIX-SACK PORTLAND CEMENT
4	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)					



**CITRUS
HEIGHTS
WATER
DISTRICT**

BLOW-OFF VALVE BOX - STREET/DRIVEWAY

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:
Robert A. Clarke
CITRUS HEIGHTS WATER DISTRICT

DATE: 4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: VB_815.DWG

PAGE:

VB_815