



CARSON 1220-4B 'T' TYPE LID:
 SHALL INCLUDE STRAIGHT TYPE
 HEXAGON LOCK-DOWN BOLT (1)
 SHALL BE MARKED "WATER"

CHRISTY FL30T RECESSED LID:
 SHALL INCLUDE STRAIGHT TYPE
 PENTAHEAD LOCK-DOWN BOLTS (2).
 SHALL BE MARKED "WATER"

METER YOKE:
 FORD, JONES, MUELLER, McDONALD

1	1" BRONZE SADDLE - IPT	10	3/4" WATER METER - RADIO READ (BY DISTRICT)
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	11	1" x 3/4" METER ADAPTORS (BY DISTRICT)
3	1" COPPER TUBING - TYPE K SOFT	12	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)
4	1" BRASS STREET ELBOW - CTS COMP x MIP	13	1" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)
5	1" BRASS STREET ELBOW	14	1" PVC CAP - SCH 40, SLIP
6	1" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP		NON-Traffic AREAS
7	1" BRASS or COPPER (AS NECESSARY TO ADJUST TO PROPER GRADE)	15	METER BOX
8	1" DUAL PURPOSE CONNECTION	16	LID
9	1" COPPER/BRASS METER YOKE - 12" HEIGHT w/2 FULL-PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET	17	2" x 6" PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
		18	3/4" CLEAN CRUSHED ROCK
		19	#2 WASHED SAND COMPACTED TO 90%
			TRAFFIC AREAS
			CARSON 1220-12
			CHRISTY FL30TBX12
			CARSON 1220-4B
			CHRISTY FL30T



**CITRUS
 HEIGHTS
 WATER
 DISTRICT**

1" WATER SERVICE - 3/4" METER NEW CONSTRUCTION

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:
Robert A. Chiles
 CITRUS HEIGHTS WATER DISTRICT

DATE: 4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_076.DWG

PAGE:

WS_076