



CARSON 1220-4B 'T' TYPE LID:  
 SHALL INCLUDE STRAIGHT TYPE  
 HEXAGON LOCK-DOWN BOLT (1)  
 SHALL BE MARKED "WATER"

CHRISTY FL30T RECESSED LID:  
 SHALL INCLUDE STRAIGHT TYPE  
 PENTAHEAD LOCK-DOWN BOLTS (2).  
 SHALL BE MARKED "WATER"

METER YOKE:  
 FORD, JONES, MUELLER, McDONALD

1	1" BRONZE SADDLE - IPT	10	1" WATER METER - RADIO READ (BY DISTRICT)
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	11	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)
3	1" COPPER TUBING - TYPE K SOFT	12	1" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)
4	1" BRASS STREET ELBOW - CTS COMP x MIP		NON-TRAFFIC AREAS
5	1" BRASS STREET ELBOW	13	METER BOX
6	1" VALVE - FULL-PORT BALL, FIP x FIP or CTS COMP x FIP	14	LID
7	1" BRASS or COPPER (AS NECESSARY TO ADJUST TO PROPER GRADE)	15	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
8	1" DUAL PURPOSE CONNECTION	16	3/4" CLEAN CRUSHED ROCK
9	1" COPPER/BRASS METER YOKE - 12" HEIGHT w/2 FULL-PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET	17	#2 WASHED SAND COMPACTED TO 90%
			TRAFFIC AREAS
		13	METER BOX
		14	LID
		15	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
		16	3/4" CLEAN CRUSHED ROCK
		17	#2 WASHED SAND COMPACTED TO 90%
			CARSON 1220-12
			CHRISTY FL30TBOX12
			CARSON 1220-4B
			CHRISTY FL30T

**1" WATER SERVICE - 1" METER  
 INCLUDING SERVICE LINE TO DWELLING**

**CITRUS HEIGHTS WATER DISTRICT**



APPROVED BY: Robert A. Clark DATE: 4/13/2009  
 CITRUS HEIGHTS WATER DISTRICT

DRAWN:	13 APR 2009
REVISED:	
SCALE:	N.T.S.
DESIGN:	P.A.D.
CAD FILE:	WS_102.DWG
PAGE:	<b>WS_102</b>