



1	1" BRONZE SADDLE - IPT	4	1" BRASS COUPLING AS REQUIRED TO CONNECT TO EXISTING 1" WATER SERVICE
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x CTS COMP	5	#2 WASHED SAND COMPACTED TO 90%
3	1" COPPER TUBING - TYPE K SOFT		

## 1" WATER SERVICE SADDLE REPLACEMENT

**CITRUS HEIGHTS WATER DISTRICT**

DRAWN: 13 APR 2009

REVISED:

APPROVED BY:

*Robert A. Chiro*

DATE: 4/13/2009

SCALE: N.T.S.

DESIGN: P.A.D.

CITRUS HEIGHTS WATER DISTRICT

CAD FILE: WS\_109.DWG

PAGE:

**WS\_109**



**CITRUS  
HEIGHTS  
WATER  
DISTRICT**