



CARSON 1220-4B "T" TYPE LID:
 SHALL INCLUDE STRAIGHT TYPE
 HEXAGON LOCK-DOWN BOLT (1)
 SHALL BE MARKED "WATER"

CHRISTY FL30T RECESSED LID:
 SHALL INCLUDE STRAIGHT TYPE
 PENTAHEAD LOCK-DOWN BOLTS (2).
 SHALL BE MARKED "WATER"

METER YOKE:
 FORD, JONES, MUELLER, McDONALD

1	1" BRONZE SADDLE - IPT	10	1" WATER METER - RADIO READ (BY DISTRICT)
2	1" CORPORATION STOP - FULL-PORT BALL, MIP x IPS COMP	11	PVC METER IDLER - 1 1/4" x 10 3/4", SCH 80 (BY CONTRACTOR)
3	1 1/4" COPPER TUBING - TYPE K SOFT	12	1" x 18" PVC NIPPLE - SCH 80 (BRASS IF BACKFLOW)
4	1" BRASS STREET ELBOW - IPS COMP x MIP	13	1" PVC CAP - SCH 40, SLIP
5	1" BRASS STREET ELBOW		
6	1" VALVE - FULL-PORT BALL, FIP x FIP or IPS COMP x FIP	14	METER BOX
7	1" BRASS or COPPER (AS NECESSARY TO ADJUST TO PROPER GRADE)	15	LID
8	1" DUAL PURPOSE CONNECTION	16	2' x 6' PRESSURE TREATED DOUGLAS FIR SUPPORTS (2)
9	1" COPPER/BRASS METER YOKE - 12' HEIGHT w/2 FULL-PORT ANGLE BALL VALVES INCLUDING PADLOCK WINGS ON INLET AND OUTLET	17	3/4" CLEAN CRUSHED ROCK
		18	#2 WASHED SAND COMPACTED TO 90%

**1 1/4" WATER SERVICE - 1" METER
 NEW CONSTRUCTION**

CITRUS HEIGHTS WATER DISTRICT



**CITRUS
 HEIGHTS
 WATER
 DISTRICT**

APPROVED BY:
Robert A. Christie
 CITRUS HEIGHTS WATER DISTRICT

DATE: 4/13/2009

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_125.DWG

PAGE:

WS_125