



| | | | |
|---|--|---|--|
| 1 | 1' BRONZE SADDLE - IPT | 5 | 1' VALVE - FULL-PORT BALL, FIP x FIP or IPS COMP x FIP |
| 2 | 1' CORPORATION STOP - FULL-PORT BALL, MIP x IPS COMP | 6 | 1' BRASS STREET ELBOW |
| 3 | 1 1/4' COPPER TUBING - TYPE K SOFT | 7 | #2 WASHED SAND COMPACTED TO 90% |
| 4 | 1' BRASS STREET ELBOW - IPS COMP x MIP | | |



**CITRUS
HEIGHTS
WATER
DISTRICT**

1 1/4" WATER SERVICE

CITRUS HEIGHTS WATER DISTRICT

APPROVED BY:

Robert A. Orrell

DATE: 4/13/2009

CITRUS HEIGHTS WATER DISTRICT

DRAWN: 13 APR 2009

REVISED:

SCALE: N.T.S.

DESIGN: P.A.D.

CAD FILE: WS_128.DWG

PAGE:

WS_128